

HBDHB CIMS INCIDENT ACTION PLAN

<p>INCIDENT NAME: Havelock North Gastro Report 2</p> <p>ACTION PLAN ISSUED BY (Section /Unit): Wietske Cloo - Exec on call</p> <p>APPROVED BY (Name):</p> <p>DATE: 13th August 2016</p> <p>TIME: 10:00hours(meeting) report 1 pm</p> <p>PRIORITY:</p> <p>EOC/ICP Location: Napier Health Centre</p> <p>CONTACT DETAILS: 027 4794813</p>	<p>Situation Summary: <i>(Brief summary of what has/is happening and what is likely to happen in the future)</i></p> <p>Havelock North water supply was chlorinated 5.30pm 12 August. Would have reached most areas by 7pm, all by 9pm. 2 parts per million, maintaining residual of .4.</p> <p>Results on water samples have confirmed presence of e-coli in Brookvale 1 and 2 bores, readings between 16 and 23. Flaxmere readings are clear.</p> <p>Water carrier who used Napier Road filling point on 10th has confirmed presence detected on 11th – tankload dumped. Readings are in the medium risk range – boiling water is necessary. E-coli will be carrying pathogens which need to be identified. Water samples have been sent to ESR. There is a water contamination event throughout Havelock North reticulation. Timeframe is somewhere between 7th and 10th August. Heavy rainfall 5th/6th – more likely to be source contamination (bore water) than anything else given scale of event. There have been earthworks close to the bores.</p> <p>Hastings Health Centre – calls over night – Te Mata Medical – 6 of 11 gastro calls through the night. ED – 8 overnight, 2 admitted, others returned home, 5 or 6 in this morning so far.</p> <p>Knowledge about a death at Mary Doyle – being investigated.. Was on noro list. (they have been in lock down for possible noro since 8th or 9th). Notice sent to all GPs this morning and to all residential care – facilities have also been rung. A + M centres informed last night.</p> <p>Media releases have gone out – Facebook (huge hit rates on both sites), Stuff, NZ Herald, HB Today. One HDC Councillor has been active ringing around resthomes intimating that they were not informed.</p>
<p>Incident Objective: <i>(What are we wanting to achieve)</i></p> <p>To determine the cause and control the outbreak of gastroenteritis in Havelock North. Prepare for health services escalation if outbreak cannot be controlled/managed within existing resources.</p>	<p>Plan of Action/Strategy: <i>(Brief summary of what we are doing and/or planning to do locally to achieve the objective)</i></p> <p>Hastings District Council To continue with chlorination and following up on water samples. To visit in person all food outlets and cafes etc in Havelock North to provide advice and guidance – liaison with MPI.</p>
<p>HBDHB - Communication Media release update – we do know it's water borne, boil water notices still apply, don't know what the bug is. Will have water results Tues/Weds. May need response to Councillor's concerns – check what has been documented. Anna and Jo to work on FAQs Public is referred to Healthline.</p> <p>HBDHB – Operations Interviews to be done on all notified cases at this stage. More lab staff on ? Check fax and Episurve for notifications. Nick to phone Mary Doyle. Hospital ED is managing – beds are available – reported by Duty Manager. Sandra to send advisory to Boarding Schools in HN – Jo to phone.</p>	<p>Plan of Action/Detailed Tasks: <i>(Summary of what each operational and supporting unit is doing and/or planning to do)</i></p> <p>Communications DHB and Hastings Council to continue to collaborate on communications with the public. Need to develop comms regarding death at Mary Doyle.</p> <p>Operations Business as usual for primary care and hospital at this stage, with increased phone calls from the public. Need to establish Planning and Intel</p> <p>Logistics Emergency department has requested extra PPE. Stores has confirmed delivery within an hour.</p>
	<p>Coordination Issues: Meetings/Briefings:</p> <p>Incident management team to meet 3pm at HBDHB EOC – off McLeod Street.</p>

<p>ESR To follow up and get timeframes for water test results. Ask for sample preservation and whether there is sufficient sample to test for crypto/shigella/salmonella.</p>	<p>Escalation Escalated to CIMS response – setting up EOC.</p>	
<p>Administration/Logistics: (Summary of personnel/logistic/resource availability and supply issues)</p> <p>Four Health Protection Officers available if needed Two Medical Officers of Health available if needed Communications team available Health Service Leadership group called in Hastings Council key staff working through weekend Population Health Admin available</p>	<p>Communications Plan: (What internal/external messages are being/are to be communicated)</p> <p>Increased rate of Gastroenteritis in Havelock North Water is being chlorinated to determine cause and community advised to boil water until further notice</p>	<p>Command and Control: Key Appointments:</p> <p>Medical Officer of Health – Nick Jones Exec on Call – Wietske Cloo Emergency Response Advisor – Sandra Bee Infection Control Advisor – Margaret Drury Duty manager</p> <p>Contact Details:</p> <p>Changeovers:</p>